



City of Austin

PUBLIC WORKS DEPARTMENT

Project Management Division

505 Barton Springs Road, Suite 900, Austin, TX 78704

Phone: (512) 974-1747

email to: sergio.altamirano@austintexas.gov

Date: January 14, 2021

PROJECT: North Side Catering and Concessions Upgrade

CIP ID: 6020.108

IFB# 6100 CLMC829

SUBJECT: Answers to Bidders Questions #2 as of the date of this letter, per 00100-IFB Article 1.(3)(C).

The following are answers to Bidders received on the above project. These answers do not modify the Contract. Any modifications to the Contract will be through Addenda

Q-1. Please confirm whether or not the RTU disconnects need to be fused.

A-1. All basis of design information for the walk-in coolers and freezer outdoor units is in the specifications on sheets A200 and A204. Disconnecting means shall meet NEC requirements.

Q-2. What height are the new ceilings supposed to be at?

A-2. Same as existing.

Sergio Altamirano
Public Works Department
Project Manager